

# Village Board Meeting

## January 2025

### Streets

- Vehicle and building maintenance have been the focus.
- Trying to get in some budget work.

### Water

- The plant is running great.
- We had another water main break. On December 21<sup>st</sup>, Mark brought to my attention that we were at double our normal use for finish water in the system. Our Finish pump at the plant had been running nonstop for a day, at that point. We split up and searched the Village for any signs of a break. We found no evidence. On Sunday, after observing for a while that the storage tank wasn't gaining, we decided to shut down the hydrant on the East end of Rt 7. This helped for the night, but we were still losing level in the storage tank. I made the call to NY Rural Water that same night to have them come out to help find this leak that was losing around 100 gpm. The next morning, they were there, and we found it on Rt 7 by Radez Ln. It was a vertical crack around an 8-inch main that we were able to put a clamp on and backfill.
- The "faulty meter report" repairs are still ongoing.

### Sewer

- The plant is running great.
- I was finally able to switch labs, that we use, for our testing at the water and sewer plant. We used the new lab, which is Capital Region Environmental, Inc. They are in Rensselaer. Mark and I made the trip out there to have a meet and greet and to see the facilities. I was impressed with the equipment they had, and the feeling of the people that work there.