

# Village Board Meeting

## March 2025

### Streets

- Vehicle and building maintenance still the focus.
- Continuing with budget work
- Jason has been repairing some potholes
- Cleaning up at the barn

### Water

- The plant is running great.
- The “faulty meter report” repairs are still ongoing. We have completed several more. Some meter changes and finding others that are not right in the computer.
- Some issues have come up that required troubleshooting. They have been solved without any disruption to the system.
- I’ve been getting info together for my AWQR, which is due in April.

### Sewer

- The plant is running great.
- I’ve completed the water withdrawal report, due annually.
- We had our annual inspection with DEC last month and I received the report for that. An overall “satisfactory” rating was given with some attention needed to certain areas. They would like the catwalks repaired for the rotors in the ditch. They would also like Mark put on as a secondary contact for NYAlert, which I will do. I told them the catwalks we’ll hopefully be addressing during the sewer project.
- We have been working with Mark Christmain, for Lamonts, with investigating what areas need attention for possible relining. We will be doing some smoke testing soon to further isolate those areas.